

Electronic copy is controlled under document control procedure. Hard copy is uncontrolled & under responsibility of beholder

It is allowed ONLY to access and keep this document with who issued, who is responsible and to whom it is applicable.

Information Security Classification: ☒ Open ☐ Shared -Confidential ☐ Shared-Sensitive ☐ Shared-Secret

People of Determination Requirements in Pharmacies (Random /Final)

Name of the Facility: _____

Date of Inspection: ____/____/____

Ref.	Description	Yes	No	Remarks
B.9.10	All health facilities are made accessible to accommodate disabled individuals. The following disability requirements are mandatory:			
C.5.8	Doors should have a free passage width of minimum 90 cm			
C.10.6	Wheelchair Ramps should be used when a change in level (step in the entrance)			
C.5.6	Counter with clear spaces to accommodate wheelchairs			
H.6.3.2	No drain grids on accessible crossings			
C.7.2.1.3	Lighting in floor (Flooring Light) not produces glare			
C.5.4	provide policy regarding the priority to providing the health care services for the OPD and fast track processing			
NA	The facility complies with Law No. (3) of 2022 Concerning the Rights of Persons with Disabilities in the Emirate of Dubai			

Checklist	ID	Issue#	Issue Date	Revision Date	Page#
Pharmacy Optics- (Random /Final)	CP_9.6_F56	01	Jun 17, 2025	Jun 17, 2028	1